

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1	OF PAGES 3
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">A001</div>		3. EFFECTIVE DATE <div style="text-align: center;">08/17/12</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">AC-12-05208</div>		5. PROJECT NO. <i>(If applicable)</i>
6. ISSUED BY FAA, MIKE MONRONEY AERONAUTICAL CENTER NAS CONTRACTING TEAM AMQ-210 P O BOX 25082 OKLAHOMA CITY OK 73125-4929				7. ADMINISTERED BY <i>(If other than Item 6)</i> FOR MORE INFORMATION CONTACT: Name: Lori Lemons Telephone No. (405) 954-5487		
8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i> All Offerors				<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. DTFAAC-12-R-05208	
					9B. DATED <i>(SEE ITEM 11)</i> 07/16/12	
				<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
*TO BE COMPLETED BY VENDOR IF NOT COMPLETE CODE _____ FACILITY CODE _____					10B. DATED <i>(SEE ITEM 13)</i>	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer is <input type="checkbox"/> extended <input checked="" type="checkbox"/> is not extended. NOTE: If offers are hand carried, additional time should be allowed to access the depository facility due to heightened security requirements. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Item 8 and 15, and returning <u>1</u> copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA <i>(If required)</i>						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.					
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation data, etc.)</i> SET FORTH IN ITEM 14,					
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
<input type="checkbox"/>	D. OTHER <i>(Specify type of modification and authority)</i>					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return 1 copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION <i>(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)</i>						
The Request for Offer referenced in Item 9A above for construction and mold remediation at the Minneapolis ARTCC, FAA F&E Building, in Farmington, MN. Is amended as follows: : 1. Page 29 of the SIR/RFO is replaced by Page 29R to add Addendum One as an attachment. 2. Addendum One is added as an attachment to provide clarification and answers to questions from the site visit. Reference Item 11 above. Acknowledge receipt of this amendment to: FAA Bid & Proposal Officer (AMQ-100) Room 313, Multi-Purpose Building 6500 South MacArthur Boulevard (P.O. Box 25082, Zip 73125-4933) Oklahoma City, OK 73169-4933						
15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>				16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
BY _____ <i>(Signature of person authorized to sign)</i>				BY _____ <i>(Signature of Contracting Officer)</i>		

PART III - SECTION J
LIST OF ATTACHMENTS

<u>Attachment</u>	<u>Title</u>	<u>Date</u>	<u>No. of Pages</u>
1	Specifications FAA-GL-2983	04/20/12	11
2	Guidelines on Assessment and Remediation Of Fungi in Indoor Environments	11/08	25
3	Mold Remediation Project Clearance Protocol	04/20/12	3
4	Microscopic Examination of Sticky Tape or Bulk Samples for the Evaluation and Identification of Fungi	NA	3
5	SCA Wage Determination No. 2005-2287, Revision 11	06/13/11	9
6	Davis Bacon Wage Determination General Decision No. MN120034 Construction Type: Building	06/01/12	7
7	Contractor's Release	05/05	1
8	Addendum One	08/16/12	2

DATE: August 17, 2012

SUBJECT: Addendum No. One to the Specifications and Drawings for construction and mold remediation at the Minneapolis ARTCC, FAA F&E Building, in Farmington, MN.

This Addendum modifies and takes precedence over the original Specifications and Drawings and forms a part of the contract documents.

Questions and Answers

Q: The drawing says to take care of 20 ln ft of the S wall in room B101E. To what height should this work be accomplished?

A: The efflorescence should be cleaned and the wall plaster repaired, primed, and painted from corner to corner up to the suspended ceiling line on the wall.

This answer will result in a nice uniform color throughout the entire wire.